



## Proposed Code Change

State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

### FOR OFFICE USE ONLY

Received 3/15/10

Code 63.5-09

#### INSTRUCTIONS:

*Only TYPED copy accepted.*

*(KEY – Dashed line through material to be deleted, underline material to be added)*

*Use second sheet for any material requiring more space.*

Code Title International Residential Code		Edition 2009
Section number and title E4002.14 Tamper-resistant receptacles		Page 706
Proponent Lynn Madden	Title	
Address 9805 Chapel Road Centerville, IN 47330		Phone 765-623-1640
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input checked="" type="checkbox"/> Delete without substitution		
<p>E4002.14 Tamper-resistant receptacles. In areas specified in Section E3901.1, 125-volt, 15- and 20-ampere receptacles shall be listed tamper-resistant receptacles.</p>		
REASON AND FISCAL IMPACT		
<p>The state's Fire Prevention &amp; Building Safety Commission removed the requirement for tamper-resistant receptacles (TRR) from the 2009 Indiana Electrical Code due to its fiscal impact.</p> <p>TRR will add approximately \$75 to the cost of every new home built in Indiana.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove 10-8 3/16/10		
Approve as amended		
Further Study		

